

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 259/25

Dated: 15-11-2025

It is certified that an inspection team headed by ...DR... ARUN KUMAR.....

(Name of Officers with designation) from ...C.M.C... Gulaothi... PHED

inspected the Modern Academy Karim Nagar Banboi BSR

(Name & Address of the school) on 07-11-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. T-9249..... dated 11-11-2025

of U.P. Jal Nigam (Rural) BSR (PHED Lab) certified that

the Modern Academy Karim Nagar Banboi BSR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12-04-2026

Signature with Seal: DR. Arun Kumar

Name: DR. Arun Kumar

Designation: B.S.R.

Name & Address of the Office/ Department: B.S.R.

To The Principal
Modern Academy Karim Nagar Banboi BSR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Manager
MODERN ACADEMY
Karimnagar, Banboi (BSR)

Principal
MODERN ACADEMY
Karim Nagar, Banboi (BSR.)



District Level Water Analysis Laboratory

UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	: T 9249	Issue Date	11/11/2025
Sample receipt Date:	: 07/11/2025	Expired Date	12/04/2026
Customer/Institution Name	: MODERN ACADEMY		
Address	: KARIMNAGAR BANKOI BULANDSHAHR		
Contact No.	: 9690504755		
Date of Sampling	: 07/11/2025	Sample Code:	B 74
Sample Description	: 07/11/2025	Quantity of Sample	1000ML
Quantity	: 1	Water Source	SAMAR SEVAL WATER
Sampling details	:	Sampling Method	As per IS 17614:Part-2021
Analysis Start	: 10/11/2025	Analysis Completion Date	11/11/2025
Temperature	: 27.1°C	Humidity	54%

Water Sample Provided ByV.P. SINGH

Availability of Equipments:		Availability of reference standards:		Adequacy of sample quantity	01
Availability of Test method:	IS 3025	Availability of Trained person:		Duration of testing/Time of Report release	10:50 pm

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	6.631	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	2.637	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	673.5	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	302	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	480	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	412	(Mg/L)*
7	Colour	APHA 23 rd Edistion	5	15	7	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca	-	75	200	145	(Mg/L)
11	Magnesium as	-	30	100	76.16	(Mg/L)

Remark

"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."



End of Report

